



**BUREAU
VERITAS**

Certificate of Conformity

Certificate No.: 1788AP0830N034006
Equipment: Hybrid inverter
Brand Name: LUXPOWER^{TEK}
Test Model No.: LXP-3K hybrid, LXP-4K hybrid, LXP-4.6K hybrid, LXP-5K hybrid
Applicant: ShenZhen Lux Power technology Co., LTD
Room 403, 4th Floor, Building 63, ZhongwuNew Industrial Park,
Zhongwu Community, Hangcheng Street, Baoan District, Shenzhen
Report No.: LD170830N034-1, LD170830N034-2

The submitted sample of the above equipment has been tested for CE marking according to following European Directive and standards:

- Low Voltage Directive 2014/35/EU.

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive.

This verification does not imply assessment of the production of the product. The CE marking may be affixed if all relevant and effective European Directives with CE are applicable.

Applied rules and standards

IEC/EN 62109-1:2010

Safety of power converters for use in photovoltaic power systems – Part 1: General requirements

IEC/EN 62109-2:2011

Safety of power converters for use in photovoltaic power systems –
Part 2: Particular requirements for inverters

IEC/EN 62040-1:2008

Uninterruptible power systems (UPS) - Part 1: General and safety requirements for UPS

Name: Ted Wu
Senior Manager/ PV Inverter Team
Date: 2017-08-18

This document shall not be reproduced, except in full, without the written approval of
Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.
Information given in this document is related to the tested specimen of the described electrical sample.